



**COUNTY OF LOS ANGELES FIRE DEPARTMENT  
FIRE PREVENTION DIVISION  
SCHOOLS & INSTITUTIONS UNIT  
7733 GREENLEAF AVENUE, WHITTIER CA 90602-2102**

**OFFICIAL INSPECTION REPORT**

Date 1/14/20

LOCAL FIRE STATION: **147**

BUSINESS NAME: **CENTRAL REGIONAL DETENTION**

CITY **LYNWOOD**

ZIP **90262**

ADDRESS: **11705 ALAMEDA ST. 90262**

RESPONSIBLE PARTY

PHONE: **323-568-4378**

EXT.:

FAX **323-415-1052**

E-MAIL: **TLFisk@lasd.org**

OCCUPANCY CLASS: **I.3**

SQFT: **30000+**

HAZ MAT HANDLER

FIRE SPRINKERS **Y**

SPRINKER SYSTEM TYPE: **1**

DENSITY / PSI:

ESFR K-FACTOR:

5-YR DUE: **DUE**

DATE OF INSPECTION: **7/26/17, 4/23/19, 6/26/19, 1/14/20**

COMPANY EMPLOYEE PRESENT DURING INSPECTION: **staff**

MARCELL BERNAL **MAINTENANCE**

PHONE NUMBER: **CELL:562-706-6980**

THE ITEMS LISTED BELOW ARE VIOLATIONS OF THE LOS ANGELES COUNTY FIRE CODE-TITLE 32, THE LOS ANGELES COUNTY BUILDING CODE-TITLE 26, AND/OR THE CALIFORNIA CODE OF REGULATIONS-TITLE 19. VIOLATIONS MUST BE CORRECTED FORTHWITH. FAILURE TO COMPLY WILL RESULT IN LEGAL ACTION; A CITATION WILL BE ISSUED, COURT APPEARANCE WILL BE REQUIRED AND A FINE MAY BE LEVIED BY THE COURT.

\*Please provide 5 yr. fire sprinkler certification, NFPA 25

\*Please provide annual fire alarm certification, NFPA 72

**INSPECTOR'S SIGNATURE**

*Jim Groff*  
Inspector GROFF

**DATE** 1/14/20

FOR INFORMATION CALL:

TEL: (562) 696-2034

FAX: (562) 945-0945